

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1250251

Product: Voltage limiting device (VLD) class 2.2

Type: BVL-50-45-R02, BVL-50-60-R02, BVL-50-120-R02, BVL-100-45-R02,
BVL-100-60-R02, BVL-100-120-R02, BVL-100-350-R02

Rating: BVL-50-...-R02: $I_r = 50$ A, $U_{Tn} = 45/60/120$ V, $I_w = 16$ kA @ 0,03 s
BVL-100-...-R02: $I_r = 100$ A, $U_{Tn} = 45/60/120/360$ V, $I_w = 16$ kA @ 0,03 s

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 251320-01/01 of: 06.06.2025

A sample of the product was found to be in conformity with:
ČSN EN 50526-2:2014 (idt EN 50526-2:2014)

Other data:

The validity of the certificate is limited to: 18.06.2028

19.06.2025

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



251320-01