

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240331

Product: Surgery protection devices (SPD) type 3 for additional installation

Type: CZ-275-A, DA-275-A, DA-275-S, CZ-275 CH, DA-275 CZS

Rating: CZ-275 CH: $U_c = 275/255$ V AC, $U_{oc} = 10$ kV
CZ-275-A: $U_c = 275/255$ V AC, $U_{oc} = 6/12$ kV
DA-275 CZS: $U_c = 275/255$ V AC, $U_{oc} = 6$ kV
DA-275-A, DA-275-S: $U_c = 275$ V AC, $U_{oc} = 4$ kV

Ordering firm: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Manufacturer: SALTEK s.r.o.
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 241509-01/01 of: 25.06.2024

A sample of the product was found to be in conformity with:
ČSN EN 61643-11 ed. 2:2013+A11:2018 (idt EN 61643-11:2012+A11:2018, mod IEC 61643-11 ed. 1.0:2011)

Other data:

The validity of the certificate is limited to: 02.07.2027

03.07.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



241509-01