

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHEISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

## CERTIFICATE

No.: 1250357

**Product:** Surge protective device (SPD) for data, signalling and telecommunications networks

**Type:** DM-006/1-R-DJ, DM-012/1-R-DJ, DM-024/1-R-DJ, DM-024/1R-VAK-DJ,  
DMG-024/1-R-DJ, DM-048/1-R-DJ, DM-012/1-L2-DJ, DM-024/1-L2-DJ,  
DM-048/1-L2-DJ

**Rating:**  $U_c = 6/11/25/36 (35,6) \text{ V AC}$ ,  $U_c = 8,5/16/36/51 (50,2) \text{ V DC}$ ,  $I_L = 0,5/2 \text{ A}$

**Ordering firm:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Manufacturer:** SALTEK s.r.o.  
Drážďanská 561/85, 400 07 Ústí nad Labem - Krásné Březno, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 252006-01/01 of: 26.08.2025

**A sample of the product was found to be in conformity with:**  
ČSN EN 61643-21:2002+A1:2010+A2:2013 (idt EN 61643-21:2001+A1:2009, A2:2013)

**Other data:**

**The validity of the certificate is limited to:** 01.09.2028

02.09.2025

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



252006-01